



## How to save 40% of energy in WTP management



**WWTPs** are responsible for 1% of the total electricity consumption in European countries;

Energy consumption of European WWTPs was 27 TWh year<sup>-1</sup>;

N<sub>2</sub>O emission from wastewater plants is **3% of global emission** (CH<sub>4</sub> is 9%);

**Electricity price** continues to score record values;

WWTPs show room for plant optimization and **reduction in energy consumption**

It becomes essential to contain costs to remain competitive in the market. Creation of **KPIs is essential to monitor the performances** and have automatic feedback.

With a focus on process optimization, it is possible to reduce chemical dosage, energy consumption, and carbon footprint.



## Case study/2: Urban WWT Plant

The Turin plant is the largest Italian WWTP (3 800 000 PE) and shall never turn off its aeration system. **An intelligent rotation** between the tanks makes it possible to alternate nitrification and denitrification, gaining a huge energy consumption reduction.

**52% energy savings** for the entire biological treatment

Area	Savings (yearly)	Economic Savings (yearly)
Blowers energy consumption	3 416 637 kWh	512 495 €
Mixed liquor pumps	1 971 000 kWh	295 650 €
<b>TOTAL</b>	<b>5 387 637 kWh</b>	<b>808 145 €</b>






## Case study/1: Urban&Industrial WWT Plant

The plant treats different industrial effluents, the management has a clear target:

Energy Savings via **Process Control Optimization**. After implementation the results are:

Pumping station specific consumption: from 0.086 a 0.058 kWh/mc (**-48.3%**)

**40%** cumulative energy savings for the entire biological treatment





## Case study/3: Industrial WWT Plant

The company is active in the treatment of **industrial wastewater**. The management needs a tool that could automatically adapt to different operating conditions. After the installation of the new control system and 2 months of monitoring activities the goals have been achieved

**55% energy savings** for the entire biological treatment

Area	Pre Oscar NO <sub>2</sub> -N (mg/l)	Post Oscar NO <sub>2</sub> -N (mg/l)	Effluent Limit NO <sub>2</sub> -N (mg/l)
Train 1	10,10	0,70	1,00
Train 2	3,00	0,40	1,00